


Calibration

AIR-SCORE



$CO_2 < 600$ ppm	A	Excellent	
$600 \text{ ppm} < CO_2 < 800$ ppm	B	Good	
$800 \text{ ppm} < CO_2 < 1000$ ppm	C	Medium	
$1200 \text{ ppm} < CO_2 < 1500$ ppm	D	Poor	
$CO_2 > 1500$ ppm	E	Inadequate	